



152 East Main Street • Forest City, NC 28043  
Phone (828) 247-4495 • Fax (828) 247-4498

## ENGINEER'S CONSTRUCTION OBSERVATION REPORT

---

Project: <b>Transfer Station Upgrades</b>	Construction Report No.: <b>1</b>
Contractor: <b>Maple Leaf Design &amp; Build, Inc.</b>	Contact at Site: <b>Bernie Dilgert</b>
Date: <b>01/24/2013</b> Time of Arrival: <b>11:30 am</b>	Weather Conditions: <b>Partly Cloudy</b>
Notice to Proceed:	Substantial Completion Date:
Previous Rain Days: <b>0</b>	Previous Substantial Completion Date:
Rain Days Since Last Report: <b>0</b> Total Rain Days <b>0</b>	Current Substantial Completion Date:

---

### Observations & Notes:

- CONTRACTOR IN THE PROCESS OF DISCONNECTING THE EXISTING HYDRANT NEAR THE METALS SEPARATING BUILDING. ROGER MOORE, BRWA, LOCATED AN INLINE VALVE THAT ALLOWED THE CONTRACTOR TO ONLY TURN THE WATER OFF AT OR TO THE METALS SEPARATING BUILDING. CONTRACTOR HOPED TO HAVE THE HYDRANT ASSEMBLY RELOCATED BY THE END OF THE DAY OR EARLY THE FOLLOWING DAY.
- NO OTHER PROBLEMS NOTED.

---

### Items Requiring Action:

**Continue to monitor installed erosion control measures in phase 1**

